

# **SPECIFICATION SHEET**

- N3HM SOLID FRONT 3 DECK MEAT/DELI/CRITICAL TEMP PRODUCE MERCHANDISERS •
- N3HMG GLASS FRONT 3 DECK MEAT/DELI/CRITICAL TEMP PRODUCE MERCHANDISERS •
- N3HME/N3HMGE 3 DECK MEAT/DELI/CRITICAL TEMP PROD. CROWN END MERCHANDISERS •

#### **Refrigeration Data:**

			CAPACITY (BTUH / FT)				DISCHARG	E AIR	AVG. REF.	
MODEL	CASE LENGTH	CASE USAGE	PARALLEL	CONVENTIONAL	(°F)	UNIT SIZING (°F)	TEMPERATURE (°F)	VELOCITY (FPM)	CHARGE (LBS/FT)	
N3HM	6'/8'/12'	MED TEMP	1,286*	1,416*	+15**	+13	+27	180***	0.18	
N3HMG	6'/8'/12'	MED TEMP	1,190*	1,310*	+15**	+13	+27	180***	0.18	
N3HME	93"	MED TEMP	7,697/case	8,102/case	+15**	+13	+27	120***	0.22	
N3HMGE	93"	MED TEMP	7,120/case	7,494/case	+15**	+13	+27	120***	0.22	

<sup>\*</sup> Capacity data listed for cases with 1 row of T-8 canopy lights and 3 rows of optional lighted shelves. Adjustments must be made to this base rating for each option installed on this case. DEDUCT 23 BTUH/FT for each row of unlighted shelves. For sizing all refrigeration equipment other than TYLER, use conventional BTUH values.

FOR SPECIFIC COMPRESSOR SIZING INFORMATION, REFER TO TYLER APPLICATIONS FOR RACK SYSTEM COMPRESSORS AND/OR THE COMPRESSOR MANUFACTURERS FOR SINGLE COMPRESSORS. FOR LINE SIZING INFORMATION, REFER TO THE MISCELLANEOUS SECTION "BUFF" IN THE TYLER SPECIFICATION GUIDE.

#### **Electrical Data:**

Fans and Heaters (120 and 208 Volt)

	OACE	FANC /	TOTAL STANDARD FANS		_	TAL FANS		TO <sup>*</sup> ANTI-SWE	208 VOLT DEFROST HEATER			
MODEL	CASE LENGTH	FANS / CASE	AMPS	AMPS WATTS		WATTS	DISCHA AMPS	DISCHARGE AIR AMPS WATTS		GLASS WATTS	AMPS	WATTS
N3HM	6'	2	1.06	96.0	0.44	22.0	0.10	12.0	N/A	N/A	6.50	1,352
N3HM	8'	2	1.06	96.0	0.44	22.0	0.13	15.6	N/A	N/A	6.90	1,436
N3HM	12'	3	1.59	144.0	0.66	33.0	0.20	24.0	N/A	N/A	10.30	2,143
N3HMG	6'	2	1.06	96.0	0.44	22.0	0.10	12.0	0.07	8.4	6.50	1,352
N3HMG	8'	2	1.06	96.0	0.44	22.0	0.13	15.6	0.09	10.8	6.90	1,436
N3HMG	12'	3	1.59	144.0	0.66	33.0	0.20	24.0	0.14	16.8	10.30	2,143
N3HM(G)E	93"	2	0.68	60.4	N/A	N/A	0.18	22.1	N/A	N/A	4.88	1,015

#### Heaters (208 Volt)

	208 VOLT DEFROST (AMPS)														
FT	6	8	12	16	20	24	28	32	36	40	44	48	52		
1 PH	6.5 TG-30	6.9 TG-30	10.3 TG-30	13.8 TG-30	17.2 TG-30	20.6 TG-30	24.1 TG-40	27.5 TG-40	30.9 TG-30	34.4 TG-50	37.8 TG-30	41.2 TG-50	44.7 TG-50		
3 PH	N/A	N/A	N/A	12.0 TG-3-30	15.0 TG-3-30	18.0 TG-3-30	15.0 TG-3-30	18.0 TG-3-30	18.0 TG-3-30	21.0 TG-3-30	25.0 TG-3-40	28.0 TG-3-40	30.0 TG-3-40		

## T-8 Lighting with Electronic Ballasts (120 Volt)

		CANOPY LIGHTS - PER ROW*					(		MAXIMUM LIGHTING (5 ROWS)				
MODEL	CASE LENGTH	AM 1-ROW	IPS 2 ROWS	WA 1-ROW	WATTS 1-ROW 2-ROWS		AMPS 1 2 3		WATTS 1 2 3			AMPS	WATTS
N3HMG	6'	0.40	0.75	48	90	0.50	0.80	1.10	60	96	132	1.85	222
N3HMG	8'	0.50	0.95	60	114	0.70	1.10	1.40	84	132	168	2.35	282
N3HMG	12'	0.70	1.40	84	168	1.05	1.65	2.10	126	198	252	3.50	420
N3HM(G)E	93"	1.06	2.12	127	254	1.06	2.12	3.18	127	255	382	5.30	636

<sup>\*</sup> Standard lighting for this case is 1 row of canopy lights.

#### **UL SANITATION** approved in accordance with ANSI/NSF – 7.

**CASE BTUH REQUIREMENTS** are calculated to produce approximately the indicated entering-air temperature with absolute maximum operating ambient limits of **75°F & 55RH**.

The information contained herein is based on technical analysis and/or tests performed in a controlled lab environment that are consistent with industry practices, and is intended as a reference for system sizing and configuration purposes only and for use by persons having technical skill at their own discretion and risk. Conditions of use are outside of Tyler's control and we do not assume and hereby disclaim any liability for results obtained or damages incurred through application of or reliance on the data presented, including but not limited to specific energy consumption with any particular model or installed application. SPECIFICATIONS ARE SUBJECT TO CHANGE WITHOUT NOTICE.

<sup>\*\*</sup> Evaporator temperature is defined as the saturated suction temperature leaving the case.

<sup>\*\*\*</sup> Air velocity measured 1 hour after defrost at the top discharge air duct using an ALNOR JR. velometer with a scoop.



## **Defrost Data:**

				EPR SET	TINGS **	DEFROST WATER				
DEFROST TYPE*	DEFROSTS PER DAY	DURATION TIME (MIN)	TERMINATION (°F)	R22 (PSIG)	R404A (PSIG)	N3HM	•	FT / DAY) N3HME	N3HMGE	
TIME OFF – N3HM(G)	6	22								
ELECTRIC - N3HM(G)	6	36	50	38	50	7.8	7.4	9.0	8.5	
HOT GAS - N3HM(G)	6	12-15	55*	30	30	7.0	7.4	9.0	0.5	
TIME OFF – N3HM(G)E	6	26								

<sup>\*</sup> If an Electronic Sensor is used for termination, it should be set at 70°F termination temperature. The sensor must be located in the same location as the defrost termination klixon for that defrost type.


**DEFROST CIRCUITS: OFF CYCLE** defrost is standard (use TC defrost module) – **OPTIONAL ELECTRIC** defrost uses a single or 3 phase circuit – **OPTIONAL HOT GAS** defrost uses 2 control wires @ 208V per lineup

	CASE-TO-CASE SUCTION LINE SUB-FEED BRANCH LINE SIZING														
MODEL 6' 8' 12' 16' 20' 24' 28' 32' 36' 40' 44' 48' 52'												52′			
N3HM(G) / R22	N3HM(G) / R22 5/8" 5/8" 7/8" 7/8" 7/8" 1 1/8" 1 1/8" 1 1/8" 1 1/8" 1 1/8" 1 3/8" 1 3/8" 1 3/8"														

CASE CIRCUITS: This case requires a 120V circuit for fans, lights and anti-sweat heaters.

Screens are standard. Shelving must be ordered separately. All rows of shelving require a shelf gasket. Shelves are available in 12", 15", 16", 18" and 20" deep sizes. When multiple shelf sizes are used, position smallest shelf size on top to largest shelf size on bottom.


### N3HM(G) CROSS SECTION




<sup>\*\*</sup> Set EPR to give this pressure at the case.



## N3HM(G) FLOOR PLAN



### N3HM(G)E FLOOR PLAN



**NOTE:** There are four separate Suction & Liquid Refrigeration Line connection points in this case. All Refrigeration Lines can connect to either side of the adjoining case-to-case lineup. The access holes in the back of the N3HME or N3HMGE case line up with the access holes in the ends of the N3HM or N3HMG case.